



**NATIONAL  
TYPE  
APPROVAL**

Certificate No: 430-8-7180

Date: 04 April 2008

**1 Certificate holder**

Name: Lime Technology Limited

Address: Unit 126, Milton Park, Abingdon Oxfordshire OX11 4SA

ian.pritchett@limetechnology.co.uk

Tel: 0845 603 1143

**2 System Title**

Description: Radical Hemcrete Walling System

**3**

The system has been assessed on the following drawings and documents:

Technical guidance sheets:-

1.01 version1 February 2008,1.02 version1 February 2008,1.03 version1 February 2008,1.04 version1

February 2008,2.01 version1 February 2008,2.02 version 4 March 2008,3.02 version1 February 2008,4.02  
version1 February 2008,5.02 version1 February 2008

solid walls formed by casting/shuttering or spraying, using a structural frame within the wall for the structural  
element and protected by a render or rain screen cladding (in accordance with the technical guidance sheets)

Extent of Recommended Regulatory Approval:

Part B: 60 minutes Fire Resistance,Part C: C2,Part L: L1(a) (i) Thermal Conductivity Value 0.679W/MK,Reg 7

**4 Assessment**

The design and method of construction of the system described in (2) above has been examined and as far as it has been shown has been found to be capable of complying with current Building Regulations.

**5 Conditions of certification**

- 1 The design shown and the materials specified shall not be changed without reference to the local authority responsible for certifying the system.
- 2 The certificate shall be valid for three years or until invalidated by formal notice.
- 3 Where reference is made on a plan to any Code of Practice, British Standard or manufacturer's instruction it shall be construed as a reference to such publication in the form in which it is in force at the date of this certificate.
- 4 This certificate should not be regarded as a formal approval under the Building Regulations.

**6 Authority**

This system approval certificate is authorised by:

Name: RICHARD BEEL

Signature: 

on behalf of: Vale of White Horse District Council